Part of MSHA Approval No. 18-A150002-0

DO NOT CHANGE WITHOUT MSHA APPROVAL

- 1. The Model TX6355 Sentro Wireless Gas Monitor is MSHA approved for use with the Energizer E95 battery only.
- 2. Do not disassemble in an area where permissibility is required, except to change eModules.
- 3. The Model TX6355 Sentro Wireless Gas Monitor is not to be used as an air quality detector per 30 CFR 75.320.
- 4. Maintain 40 inches between the Model TX6355 Sentro Wireless Gas Monitor and any blasting circuits, explosives and detonators.
- 5. Only equipment with model number TX6355.04.02 and fitted with a CO sensing eModule with part number TX6350.04.250.50 or TX6350.04.250.500 is approved by QPS (NRTL tested) to ANSI/ISA 92.00.01 (Toxic Gas Performance) for CO gas detection. Therefore, only this equipment is accepted by MSHA for compliance with 30CFR75.351 or 75.1103.

Issue	А	В				TX6355.04.nn Sentro Wireless Gas Detector - Conditions of Use			
ECR	4298	5009							
App'd	AH	AH				Document No: P5596.1800			
Date	04/04/16	16 Jan 2020				Dr'n AH	16 Jan 2020	Ch'd NC	16 Jan 2020



TROLEXX Trolex Ltd. Newby Road, Hazel Grove, Stockport, Cheshire, SK7 5DY. UK. t:+44(0)161 483 1435 e: sales@trolex.com w: www.trolex.com | www.methanemonitoring.net

