

**Australian/New Zealand
Certification Scheme for
EXPLOSION-PROTECTED ELECTRICAL EQUIPMENT
ANZEx Scheme**

Certificate of Conformity

Certificate No.: ANZEx 14.3006X

Issue No.: 0

Date of Issue: 20/02/2014

Applicant: Trox Limited
Newby Road, Hazel Grove
Stockport SK7 5DY
United Kingdom

Electrical Apparatus: TX6641 Intrinsically Safe Power Supply Chassis

Type of Protection: [Ex ia]

Marking Code: Trolex Limited
TX6641 Intrinsically Safe Power Supply Chassis
[Ex ia] I (-20 °C ≤ T_{amb} ≤ +55 °C)
ANZEx 14.3006X
S/N _____

Manufacturer: Trolex Limited
Newby Road, Hazel Grove
Stockport SK7 5DY
United Kingdom

Manufacturing Location(s): As above

The EPEE certification database located at <http://www.anzex.com.au> shows the validity of this Certificate.

This certificate and schedule shall not be reproduced except in full

| | | |
|---|---|---|
|  | <p>Certificate issued by:</p> <p style="text-align: center;">TestSafe Australia 919 Londonderry Road, Londonderry NSW 2753 Australia Phone: +61 2 4724 4900 Fax: +61 2 4724 4999 http://www.testsafe.com.au</p> |  <p>www.jas-anz.org/register</p> |
|---|---|---|

**Australian/New Zealand
Certification Scheme for
EXPLOSION-PROTECTED ELECTRICAL EQUIPMENT
ANZEx Scheme**

Certificate of Conformity

Certificate No.: ANZEx 14.3006X

Issue No.: 0

Date of Issue: 20/02/2014

This certificate is granted subject to the conditions as set out in Standards Australia/Standards New Zealand Miscellaneous Publication MP87.1:2008.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0:2011 Explosive atmospheres – Part 0: Equipment – General requirements

IEC 60079-11:2011 Explosive atmospheres – Part 11: Equipment protection by intrinsic safety “i”

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standard(s) listed above.*

ASSESSMENT & TEST REPORTS:

The equipment listed has successfully met the assessment and test requirements as recorded in:

Test Report No. and Issuing Body: **34540, TestSafe**

Quality Assessment Report No. and Issuing Body: **GB/SIR/QAR07.0017/04**

File Reference: **2013/002568**



Ujen Singh

Signed for and on behalf of issuing body

20/02/2014

Date of Issue

Quality & Certification Manager

Position

**This certificate is not transferable and remains the property of the issuing body
and must be returned in the event of it being revoked or not renewed.**

This certificate and schedule shall not be reproduced except in full

**Australian/New Zealand
Certification Scheme for
EXPLOSION-PROTECTED ELECTRICAL EQUIPMENT
ANZEx Scheme**

Certificate of Conformity

Certificate No.: ANZEx 14.3006X

Issue No.: 0

Date of Issue: 20/02/2014

Schedule

EQUIPMENT:

The TX6641 Power Supply Chassis is designed to provide an intrinsically safe supply primarily to intrinsically safe equipment. The power supply chassis comprises a printed circuit board (PCB) that accommodates an intrinsically safe transformer, voltage clamping components, current and power limiting circuitry.

The Power Supply TX6641 must be housed in a suitably certified Ex d enclosure when used in a hazardous area. When used in a non-hazardous area it must be housed inside an enclosure that affords a degree of protection of at least IP20.

The connection to external hazardous area apparatus is made via connector J7.

The Power Supply is available in various options providing differing output voltages, currents, input voltages, and optionally fitted with up to two relay boards providing up to 4 relay interfaces.

CONDITIONS OF CERTIFICATION:

1. It is a condition of manufacture that the mains transformer shall be subjected to routine tests and be able to withstand a test voltage of at least 2500 V applied between primary and secondary windings, and at least 1500 V applied between all windings and the core or screen.
2. It is a condition of safe use that the Power Supply TX6641 must be housed in a suitably certified Ex d enclosure when used in a hazardous area. When used in a non-hazardous area it must be housed inside an enclosure that affords a degree of protection of at least IP20.
3. It is a condition of safe use that the TX6641 circuits must have infallible creepage and clearance distances to the enclosure walls, as defined by clause 6.3 of IEC 60079-11.
4. It is a condition of safe use that the connections to the relay boards must both be configured as either to IS circuits or non-IS circuits. It is not permitted to mix the connection of IS and non-IS circuits to these relays.
5. It is a condition of safe use that the wiring carrying non-hazardous area circuits to the relays must be routed to ensure that they are segregated from hazardous area circuits, maintaining compliance with Table 5 of IEC 60079-11:2011, namely 6 mm of clearance through air and/or 1 mm clearance through solid insulation.
6. It is a condition of safe use that the following parameters are taken into account in the installation:

| Product Code | PSU Type | U _o | I _o | P _o | C _o | Lo/Ro |
|--------------|-------------|----------------|----------------|----------------|----------------|-------------------------|
| 109.1205 | 7.7 V 0.5 A | 8.5 V | 0.873 A | 5.28 W | 646 μ F | 72.69 μ H/ Ω |
| 109.1204 | 7.7 V 1.0 A | 8.5 V | 1.76 A | 10.63 W | 560 μ F | 36.17 μ H/ Ω |
| 109.1203 | 7.7 V 1.4 A | 8.5 V | 1.76 A | 10.63 W | 560 μ F | 36.17 μ H/ Ω |

This certificate and schedule shall not be reproduced except in full

**Australian/New Zealand
Certification Scheme for
EXPLOSION-PROTECTED ELECTRICAL EQUIPMENT
ANZEx Scheme**

Certificate of Conformity

Certificate No.: ANZEx 14.3006X

Issue No.: 0

Date of Issue: 20/02/2014

| Product Code | PSU Type | Uo | Io | Po | Co | Lo/Ro |
|----------------|---------------|---------|---------|---------|---------------|-------------------------|
| 109.1202 | 7.7 V 1.8 A | 8.5 V | 1.76 A | 10.63 W | 560 μ F | 36.17 μ H/ Ω |
| 101.1205 | 12.35 V 0.5 A | 13.0 V | 0.873 A | 6.33 W | 32 μ F | 72.69 μ H/ Ω |
| 101.1204 | 12.35 V 1.0 A | 13.0 V | 1.76 A | 12.73 W | 30.29 μ F | 36.17 μ H/ Ω |
| 101.1203 | 12.35 V 1.4 A | 13.0 V | 2.38 A | 17.23 W | 19.46 μ F | 26.72 μ H/ Ω |
| 101.1202 | 12.35 V 1.8 A | 13.0 V | 2.38 A | 17.23 W | 19.46 μ F | 26.72 μ H/ Ω |
| 101.1204 (alt) | 12.35 V 1.0 A | 12.35 V | 1.8 A | 10.45 W | 30 μ F | 44.63 μ H/ Ω |

| Product Code | PSU Type | Um (Terminals marked 'ac Supply') |
|--------------|--------------------|-----------------------------------|
| 103 | 24 V rms supply | 24 V rms |
| 105 | 110 V rms supply | 110 V rms |
| 106 | 230 V mains supply | 230 V rms |

| Product Code | PSU Type | Terminals marked R1, R2, R3, R4 | |
|--------------|-------------------------|---------------------------------|-------------|
| 19 | Fitted with Relay board | Um: 375 V rms | Im: 5 A rms |
| | | or | |
| | | Ui: 30 V | Ii: 5 A |

DOCUMENTS:

| Document Number | Document Title | Revision | Date |
|------------------|---|----------|------------|
| P5531.01 2 Shts. | Power Supply Certified Circuit Diagram | E | 2003-03-11 |
| P5531.01 2 Shts. | Power Supply Certified Circuit Diagram | F | 2004-07-26 |
| P5531-02-01 | General Arrangement (TX6641 Power Supply Chassis) | C | 2003-06-16 |
| P5531.03.01 | PCB Bottom Layer | A | 2001-09-21 |
| P5531.03.02 | PCB Bottom Overlay | A | 2001-09-21 |

This certificate and schedule shall not be reproduced except in full

**Australian/New Zealand
Certification Scheme for
EXPLOSION-PROTECTED ELECTRICAL EQUIPMENT
ANZEx Scheme**

Certificate of Conformity

Certificate No.: ANZEx 14.3006X

Issue No.: 0

Date of Issue: 20/02/2014

| Document Number | Document Title | Revision | Date |
|-------------------|--|----------|------------|
| P5531.03.03 | PCB Inner Layer 1 | A | 2001-09-21 |
| P5531.03.04 | PCB Inner Layer 2 | A | 2001-09-21 |
| P5531.03.05 | PCB Top Layer | A | 2001-09-21 |
| P5531.03.06 | PCB Top Overlay | A | 2001-09-21 |
| P5531.04 | Transformer (Certification Details) | C | 2002-01-16 |
| P5531.04.01 | Transformer (24Vac) (Certification Details) | C | 2002-01-16 |
| P5531.06 | Relay PCB Connections | A | 2001-10-10 |
| P5531-99 | Certification Labelling - Australia | B | 2014-02-05 |
| P5111.89 | PCB Artwork | A | 1996-12-11 |
| P5531.107 2 shts. | Input regulator and reset PCB Certified circuit diagram | A | 2003-03-06 |
| P5531.107 2 shts. | Input regulator and reset PCB Certified circuit diagram and parts list | C | 2003-11-20 |
| P5531.106 | Regulator Reset PCB | A | 2003-06-04 |
| P5531.106 | Regulator Reset PCB | B | 2004-01-15 |
| P5531-108 | Fuse, potted. | B | 2003-06-12 |

This certificate and schedule shall not be reproduced except in full