



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX CML 20.0158X** Page 1 of 3 [Certificate history:](#)
Status: **Current** Issue No: 0
Date of Issue: 2021-04-29
Applicant: **Trolex Ltd**
Newby Rd
Hazel Grove
Stockport
Cheshire, SK7 5DY
United Kingdom
Equipment: **Sentro 1 Sensor/Transmitters TX635x.01i.xx.35(.xx) and TX9081.01i.xx.35(.xx)**
Optional accessory:
Type of Protection: **Intrinsic Safety**
Marking: Ex ia I Ma
Ta = -20°C to +40°C

Approved for issue on behalf of the IECEx
Certification Body:

A Snowdon MIET

Position:

Assistant Certification Manager

Signature:
(for printed version)

A Snowdon

Date:

2021-04-29

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Eurofins E&E CML Limited
Unit 1, Newport Business Park
New Port Road
Ellesmere Port, CH65 4LZ
United Kingdom





IECEX Certificate of Conformity

Certificate No.: **IECEX CML 20.0158X**

Page 2 of 3

Date of issue: 2021-04-29

Issue No: 0

Manufacturer: **Trolex Ltd**
Newby Rd
Hazel Grove
Stockport
Cheshire, SK7 5DY
United Kingdom

Additional
manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[GB/CML/ExTR20.0231/00](#)

Quality Assessment Report:

[GB/SIR/QAR07.0017/10](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX CML 20.0158X**

Page 3 of 3

Date of issue: 2021-04-29

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The Sentro 1 Sensor/Transmitters TX635x.01i.xx.35(.xx) and TX9081.01i.xx.35(.xx) monitor an input from sensor modules. The sensor module is fully integrated into the base unit to give direct monitoring of oxygen, toxic or flammable gas concentrations (versions with eModules), or alternatively the monitoring channel may be connected to a remote sensor to measure airflow, pressure, vibration, etc (versions with rModules).

See Annex for full description and conditions of manufacture.

SPECIFIC CONDITIONS OF USE: YES as shown below:

See Annex for Specific Conditions of Use.

Annex:

[IECEX CML 20.0158X Annex Issue 0.pdf](#)

Annexe to: IECEx CML 20.0158X, Issue 0
Applicant: Trolex Ltd.
Apparatus: Sentro 1 Sensor/Transmitters
TX635x.01i.xx.35(.xx) and
TX9081.01i.xx.35(.xx)



Description

The Sentro 1 Sensor/Transmitters TX635x.01i.xx.35(.xx) and TX9081.01i.xx.35(.xx) monitor an input from sensor modules. The sensor module is fully integrated into the base unit to give direct monitoring of oxygen, toxic or flammable gas concentrations (versions with eModules), or alternatively the monitoring channel may be connected to a remote sensor to measure airflow, pressure, vibration, etc (versions with rModules).

The equipment may be fitted with various gas sensing modules (eModules) and various terminal modules (rModules) for remote connection of external sensors.

The unit comprises a Control PCB, Display PCB and an Output PCB housed in a non-metallic enclosure with polycarbonate LCD window which provides a degree of protection of at least IP54. External circuit connections are made through the two gland entries at the bottom of the housing, and via terminals on the front of the unit (rModules).

The Output PCB may be fitted in one of the following variants:

- Relay Output PCB
- Analogue/Comms Output PCB - 0.4V - 2V Output
- Analogue/Comms Output PCB - 4mA - 20mA Output
- Analogue/Comms Output PCB - RS485 Output
- 4-20mA Loop Powered Output PCB

The following table details the various build options of the base unit:

Base model no.	Output Type	Module type
TX6351.01i.11.35(.xx)	0.4V – 2V	eModule
TX6351.01i.12.35(.xx)	4mA – 20mA	
TX6351.01i.15.35(.xx)	RS485	
TX6351.01i.14.35(.xx)	Relays NC	
TX6351.01i.17.35(.xx)	Relays NO	
TX6352.01i.12.35(.xx)	4-20mA loop powered	eModule
TX9081.01i.11.35(.xx)	0.4V – 2V	rModule
TX9081.01i.12.35(.xx)	4mA – 20mA	
TX9081.01i.15.35(.xx)	RS485	
TX9081.01i.14.35(.xx)	Relays NC	
TX9081.01i.17.35(.xx)	Relays NO	

NOTE – only models with digits 35 after the output type option digits are covered by this certificate.

Unit 1, Newport Business Park
New Port Road
Ellesmere Port
CH65 4LZ

T +44 (0) 151 559 1160
E info@cmllex.com

www.cmllex.com

Company Reg No. 8554022 VAT No. GB163023642



The eModules and rModules may be any of the following types:

Type	Part no.	Description
eModule	TX6350.35(.XX...)	Infra red
	TX6350.35(.XX...)	Toxic gas and oxygen
	TX6350.35(.XX...)	Flammable gas
rModule	TX9160.01i.301.35(.XX..)	4-20mA input
	TX9160.01i.303.35(.XX..)	0.4V – 2V input
	TX9160.01i.306.35(.XX..)	PT100 input
	TX9160.01i.501.35(.XX..)	NAMUR input
	TX9160.01i.502.35(.XX..)	Switch input

NOTE – only models with digits 35 before the final option digits are covered by this certificate.

Intrinsic safety is achieved by limiting energy storage and discharge, and by connecting to the non-hazardous area via intrinsically safe interface devices.

The equipment has the following safety description:

Model No.	Power Input	Output type	Output
TX6351.01i.11.35(.xx) TX9081.01i.11.35(.xx)	Terminal 5 w.r.t. 6 U _i = 14.4V C _i = 0 L _i = 0	0.4V – 2V	Terminal 1 w.r.t. 2 or 3 U _i = 14.4V U _o = 14.4V I _o = 40mA P _o = 0.135W C _i = 0 L _i = 0
TX6351.01i.12.35(.xx) TX9081.01i.12.35(.xx)	U _i = 14.4V C _i = 0 L _i = 0	4mA – 20mA	Terminal 1 w.r.t. 2 or 3 U _i = 14.4V U _o = 14.4V I _o = 0.477A P _o = 1.72W C _i = 0 L _i = 0

Model No.	Power Input	Output type	Output
TX6351.01i.15.35(.xx) TX9081.01i.15.35(.xx)		RS485	Terminal 1 w.r.t. 3 (RS485 A) Terminal 2 w.r.t. 3 (RS485 B) Parameters for each output: U _i = 6.88V U _o = 5.88V C _i = 0 I _o = 66mA L _i = 0 P _o = 97mW
TX6351.01i.14.35(.xx) TX9081.01i.14.35(.xx)		Relays NC	Terminal 1 w.r.t. 2 (Relay 1) Terminal 3 w.r.t. 4 (Relay 2) U _i = 30V U _o = 0 C _i = 0 I _o = 0 L _i = 0 P _o = 0
TX6351.01i.17.35(.xx) TX9081.01i.17.35(.xx)		Relays NO	Terminal 1 w.r.t. 2 (Relay 1) Terminal 3 w.r.t. 4 (Relay 2) U _i = 30V U _o = 0 C _i = 0 I _o = 0 L _i = 0 P _o = 0
TX6352.01i.12.35(.xx)	Terminal 1 w.r.t. 2 U _i = 14.4V C _i = 0 L _i = 0	Loop powered	N/A

rModules have the following output parameters:

Model No.	Output type	Output terminals
TX9160.01i.301.35(.XX..)	4-20mA input	Terminal 1m w.r.t 3m Output parameters same as external supply Terminal 2m w.r.t 3m Uo = 14.4V Io = 3.5mA Po = 12mW Ci = 0 Li = 0
TX9160.01i.303.35(.XX..)	0.4V – 2V input	Terminal 1m w.r.t 3m Output parameters same as external supply Terminal 2m w.r.t 3m Uo = 14.4V Io = 3.5mA Po = 12mW Ci = 0 Li = 0
TX9160.01i.306.35(.XX..)	PT100 input	Terminals 1m and 2m (combined) w.r.t. 3m Uo = 14.4V Io = 55mA Po = 0.20W Ci = 0 Li = 0
TX9160.01i.501.35(.XX..)	NAMUR input	Terminal 1m w.r.t. terminal 2m Uo = 14.4V Io = 46mA Po = 0.16W Ci = 7.08μF Li = 0
TX9160.01i.502.35(.XX..)	Switch input	Terminal 1m w.r.t. terminal 2m Uo = 14.4V Io = 46mA Po = 0.16W Ci = 7.08μF Li = 0

Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. Where the product incorporates certified parts or safety critical components, the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate.

Specific Conditions of Use

The following conditions relate to safe installation and/or use of the equipment.

- i. Where an external sensor is used with either rModule type TX9160.01i.301.35 (4-20mA) or TX9160.01i.303.35 (0.4-2V) and it is powered from an external supply, the following shall apply
 - No connection shall be made to the power terminal 1m
 - The 0V of the external sensor supply shall be connected to the 0V of the Sentro supply
- ii. rModule types TX9160.01i.306.35 (PT100), TX9160.01i.501.35 (NAMUR), and TX9160.01i.502.35 (switch) shall not be used with externally powered sensors.
- iii. The cable entries to the supply and output terminals shall be made via cable glands which provide a minimum degree of protection of IP54.
- iv. Under certain extreme circumstances, unearthed metal parts of the enclosure may store an ignition-capable level of electrostatic charge. The equipment shall either be earthed via the integral earthing terminal or the user/installer shall implement precautions to prevent the build-up of electrostatic charge. When not earthed, the capacitance of the metallic label to earth is >10pF.

Components covered by Ex Certificates issued to older editions of Standards

Certificate number	Standards (incl Ed)	Assessment result
IECEX SIR 07.0050U	IEC 60079-0 Ed 6	Technical differences evaluated and found satisfactory. For detail see ExTR
IECEX SIR 05.0030U	IEC 60079-0 Ed 6	
IECEX SIR 12.0139U	IEC 60079-0 Ed 6	