



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEX BAS 15.0065X	Page 1 of 5	<u>Certificate history:</u>
Status:	Current	Issue No: 2	Issue 1 (2017-08-04) Issue 0 (2015-06-16)
Date of Issue:	2023-09-07		
Applicant:	Trolex Limited 10a Newby Road Hazel Grove Stockport Cheshire SK7 5DY United Kingdom		
Equipment:	TX9042 Programmable Sensor Controller		
Optional accessory:			
Type of Protection:	Intrinsic Safety		
Marking:	Ex ia I Ma (-20°C ≤ Ta ≤ +40°C)		

Approved for issue on behalf of the IECEx
Certification Body:

R S Sinclair

Position:

Technical Manager

Signature:
(for printed version)

Date:
(for printed version)

7/9/2023

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

SGS UK Limited
Rockhead Business Park
Staden Lane
Buxton, Derbyshire SK17 9RZ
United Kingdom





IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 15.0065X**

Page 2 of 5

Date of issue: 2023-09-07

Issue No: 2

Manufacturer: **Trox Limited**
10a Newby Road
Hazel Grove
Stockport
Cheshire
SK7 5DY
United Kingdom

Manufacturing locations: **Trox Limited**
10a Newby Road
Hazel Grove
Stockport
Cheshire
SK7 5DY
United Kingdom

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC 60079-11:2023](#) Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:7.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[GB/BAS/ExTR15.0149/00](#)

[GB/BAS/ExTR17.0194/00](#)

[GB/SGS/ExTR23.0096/00](#)

Quality Assessment Report:

[GB/SIR/QAR07.0017/12](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 15.0065X**

Page 3 of 5

Date of issue: 2023-09-07

Issue No: 2

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The Programmable Sensor Controller Type TX9042 provides signal conditioning and monitoring for up to 8 transducers. Each transducer is connected via a dedicated Input PCB which provides the signal conditioning. A programmable microprocessor circuit monitors the conditioned signals to provide local display, monitoring and control signals, and digital data transmission.

The electronic circuitry, comprising up to 13 PCBs (Power Supply module, Display PCB, Control PCB, Input PCB, Comms Module and up to 8 'Input' Modules), is housed in a moulded plastic enclosure which is itself housed in a stainless steel outer enclosure that provides facilities such as gland entries for restraining incoming cables. This enclosure has been assessed as providing a degree of protection of not less than IP54.

The Control PCB carries the microprocessor circuitry and control relays and is mounted in the centre of the moulded enclosure; mounted over this, fixed to the top of the enclosure and connected to the Control PCB by a flat ribbon connector, is the Display PCB. An LCD is fitted on the Display PCB along with a connector to interface with a membrane keypad moulded into the top of the unit; the relay status LEDs and a piezo-electric buzzer are also mounted on the Display PCB. Optional data link circuitry is fitted onto a small daughter board (Digital Comms, RS485 Comms) which has pins for connection onto the Control PCB.

An Input PCB, fitted below the Control PCB, carries up to eight transducer 'Input Modules' which can be selected from the following list and fitted in any position on the Input PCB. Each Input Module is a small PCB fitted with input terminals and signal processing circuitry.

Continued on Page 4:

SPECIFIC CONDITIONS OF USE: YES as shown below:

1. The Programmable Sensor Controller Type TX9042 must be mounted in a secondary enclosure as shown on drawing P5423.02 or in an alternative metal enclosure (not light alloys) which is appropriately certified as providing a degree of protection of IP54.
2. Up to 11 RS485 Comms Modules (in separate Programmable Sensor Controllers type TX9042) may be daisy-chained together (i.e. terminals B1 all linked together, terminals B2 all linked together and terminals B3 all linked together). Provided that the number of daisy-chained PSC's is reduced to 10, these comms lines may be connected to unspecified safe area equipment via an appropriately certified shunt zener diode safety barrier (dual channel a.c.), whose output parameters do not exceed the following per channel:

$$U_o = 9 \text{ V}, I_o = 100 \text{ mA}, P_o = 225 \text{ mW}$$

$$\text{OR } U_o = 12 \text{ V}, I_o = 80 \text{ mA}, P_o = 240 \text{ mW}$$

e.g. suitably certified MTL 761, MTL766 to IECEx BAS 05.0019 or MTL7761ac, MTL7766ac to IECEx BAS 04.0025.

For the purposes of this certificate, these shunt zener safety barriers may be considered equivalent to Category I (M1) equipment. The cable parameters shall not exceed the following: $C_c = 2.8 \mu\text{F}$, $L_c/R_c = 222 \mu\text{H}/\Omega$.

3. For the purpose of this certificate, a P+F Cylindrical Inductive Proximity Sensor Type NC... and NJ... to PTB00ATEX2048X to Ex ia IIC T6 connected to terminals T1 to T4 of a Digital Input Module may be considered equivalent to Ex ia I Mb. In this instance, the power supply selected to power the PSC must have an output voltage not exceeding 16V.



IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 15.0065X**

Page 4 of 5

Date of issue: 2023-09-07

Issue No: 2

Equipment (continued):

The Input Modules comprise:

DC Analogue Input (that can be configured for voltage, current or temperature input)
Digital Input (with an option of Vortex input)
Digital Input (Failsafe)
AC (RMS) Analogue Input
Thermocouple Input
Strain Gauge Input
Flow Sensor Input
Alternative Flow Sensor Module (Variation 1)

A Power Supply Module connects to the underside of both the Input PCB and the Control PCB.
Connections between the modules, Input PCB, Power Supply Module and Control PCB are by PCB-mounted two-part connectors.

Connections to external power sources can be made at :

Terminals A17, A18 - input to Power Supply Module
Terminals B1 to B6 - Digital comms
Terminals B7 to B18 - Relay contacts (3 contacts per relay)
Terminals A1 to A16, A19 to A34 - Input Modules (4 terminals per module)



IECEX Certificate of Conformity

Certificate No.: **IECEX BAS 15.0065X**

Page 5 of 5

Date of issue: 2023-09-07

Issue No: 2

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Variation 1.1

This issue confirms that the current design meets the requirements of IEC 60079-0:2017 & IEC 60079-11:2023; the equipment is already marked in accordance with the requirements of these standards.

ExTR: **GB/SGS/ExTR23.0096/00**

File Reference: **23/0161**

Annex:

[IECEX BAS 15.0065X Annex.pdf](#)

Power Supply Connection

Terminals A17, A18 (Power)

$$\begin{aligned} U_i &= 16.5 \text{ V} \\ C_i &= 0 \\ L_i &= 0 \end{aligned}$$

Terminals A35, A36 (Control Function)

$$\begin{aligned} U_i &= 0 \\ I_i &= 0 \\ P_i &= 0 \\ C_i &= 0 \\ L_i &= 0 \end{aligned}$$

DC Analogue Input Module Connections

This module may be configured, when ordered, for any one of three types of signal input – voltage, current or temperature:

Voltage Input:

Power Output Terminal T1 w.r.t. T4

$$\begin{aligned} U_o &= U_i \text{ (power supply connection)} \\ I_o &= * \\ P_o &= * \\ C_o &= * \\ L_o &= * \\ L_o/R_o &= * \end{aligned}$$

Input Terminals T2, T3 w.r.t. T4

$$\begin{aligned} U_i &= 16.5 \text{ V} & U_o &= 6.51 \text{ V} \\ C_i &= 120 \text{ nF} & I_o &= 1.3 \text{ mA} \\ L_i &= 0 & C_o &= 300 \text{ }\mu\text{F} \\ & & L_o &= 100 \text{ mH} \end{aligned}$$

Note: parameters marked * are obtained from the certification documents of the power supply connected.

Current Input:

Power Output Terminal T1 w.r.t. T2

$$\begin{aligned} U_o &= U_i \text{ (power supply connection)} \\ I_o &= * \\ P_o &= * \\ C_o &= * \\ L_o &= * \\ L_o/R_o &= * \end{aligned}$$

Input Terminal T2 w.r.t. T3 or T4

$$\begin{aligned} U_i &= 16.5 \text{ V} & U_o &= 6.51 \text{ V} \\ C_i &= 120 \text{ nF} & I_o &= 1.3 \text{ mA} \\ L_i &= 0 & C_o &= 300 \text{ }\mu\text{F} \\ & & L_o &= 100 \text{ mH} \end{aligned}$$

Note: parameters marked * are obtained from the certification documents of the power supply connected.

Temperature Input:

Power Output Terminal T1 w.r.t. T2, T3 or T4

$$\begin{aligned} U_o &= U_i \text{ (power supply connection)} \\ I_o &= 10\text{mA} \\ P_o &= 42\text{mW} \\ C_o &= * \\ L_o &= * \\ L_o/R_o &= * \end{aligned}$$

Input Terminal T2 w.r.t. T3 or T4

$$\begin{aligned} U_i &= 16.5 \text{ V} & U_o &= 6.51 \text{ V} \\ C_i &= 120 \text{ nF} & I_o &= 1.3 \text{ mA} \\ L_i &= 0 & C_o &= 100 \text{ }\mu\text{F} \\ & & L_o &= 100 \text{ mH} \end{aligned}$$

Note: parameters marked * are obtained from the certification documents of the power supply connected.

Digital Input Module Connections

This module can be configured as either of two versions, digital and vortex:

Digital Input

Power Output Terminal T1 w.r.t. T4

$U_o = U_i$ (power supply connection)
 $I_o = 40$ mA
 $P_o = 163$ mW
 $C_o = 5$ μ F
 $L_o = 5$ mH
 $L_o/R_o = 100$ μ H/ Ω

Input Terminals T2, T3

$U_i = 16.5$ V $U_o = 6.51$ V
 $C_i = 0$ $I_o = 16$ mA
 $L_i = 0$ $C_o = 100$ μ F
 $L_o = 100$ mH

Vortex Input

Power Output Terminal T1 w.r.t. T4

$U_o = 6.51$ V
 $I_o = 40$ mA
 $P_o = 153$ mW
 $C_o = 100$ μ F
 $L_o = 26$ mH
 $L_o/R_o = 240$ μ H/ Ω

Input Terminals T2, T3

$U_i = 16.5$ V $U_o = 6.51$ V
 $C_i = 0$ $I_o = 7$ mA
 $L_i = 0$ $C_o = 100$ μ F
 $L_o = 100$ mH

Digital Input (Failsafe) Module Connections

Power Output Terminals T1 or T3 w.r.t. T2 or T4

$U_o = 12.51$ V $U_i = 0$ V
 $I_o = 3.4$ mA
 $P_o = 10.5$ mW
 $C_o = 5$ μ F
 $L_o = 10$ mH

Input Terminals T2, T4

$U_i = 16.5$ V $U_o = 6.51$ V
 $C_i = 12$ nF $I_o = 3.6$ mA
 $L_i = 0$ $C_o = 100$ μ F
 $L_o = 100$ mH

AC (rms) Analogue Input Module Connections

Power output Terminal T1 w.r.t. T4

$U_o = U_i$ (power supply connection)
 $I_o = *$
 $P_o = *$
 $C_o = *$
 $L_o = *$
 $L_o/R_o = *$

Loop power Output Terminal T2 w.r.t. T3 or T4

$U_i = 16.5$ V $U_o = U_i$ (power supply connection)
 $C_i = 12$ nF $I_o = 121$ mA at $U_i = 16.5$ V
 $L_i = 0$ $P_o = 497$ mW at $U_i = 16.5$ V
 $C_o = *$
 $L_o = 30$ mH

Note: parameters marked * are obtained from the certification documents of the power supply connected.

Thermocouple Input Module Connections

Power output Terminal T1 w.r.t. T4

$U_o = U_i$ (power supply connection)
 $I_o = *$
 $P_o = *$
 $C_o = *$
 $L_o = *$
 $L_o/R_o = *$

Input Terminals T2, T3 w.r.t. T4

$U_i = 6.88$ V $U_o = 6.51$ V
 $C_i = 0$ $I_o = 16$ mA
 $L_i = 0$ $C_o = 100$ μ F
 $L_o = 100$ mH

Note: parameters marked * are obtained from the certification documents of the power supply connected.

Strain Gauge Input Module Connections

Power Output Terminal T1 w.r.t.T4

$U_o = U_i$ (power supply connection)
 $I_o = 129 \text{ mA}$ at $U_i = 16.5 \text{ V}$
 $P_o = 0.53 \text{ W}$ at $U_i = 16.5 \text{ V}$
 $C_o = *$
 $L_o = *$
 $L_o/R_o = *$

Note: parameters marked * are obtained from the certification drawings of the power supply connected.

Input Terminals T2, T3 w.r.t. T4

$U_i = 16.5 \text{ V}$ $U_o = 6.88 \text{ V}$
 $P_i = 0.53 \text{ W}$ $I_o = 21 \text{ mA}$
 $C_i = 10 \text{ nF}$ $C_o = 100 \mu\text{F}$
 $L_i = 0$ $L_o = 100 \text{ mH}$

Flow Sensor Input Module Connections

Power Output Terminal T1 w.r.t.T4

$U_o = 7.14 \text{ V}$
 $I_o = 131 \text{ mA}$
 $P_o = 234 \text{ mW}$
 $C_o = 100 \mu\text{F}$
 $L_o = 10 \text{ mH}$
 $L_o/R_o = 1834 \mu\text{H}/\Omega$

Input Terminal T2 w.r.t.T4

$U_i = 7.14 \text{ V}$ $U_o = 6.88 \text{ V}$
 $C_i = 1.1 \text{ nF}$ $I_o = 3.3 \text{ mA}$
 $L_i = 0$ $C_o = 100 \mu\text{F}$
 $L_o = 100 \text{ mH}$

Input Terminal T3 w.r.t. T4

$U_i = 16.5 \text{ V}$ $U_o = 6.88 \text{ V}$
 $C_i = 1.1 \text{ nF}$ $I_o = 3.3 \text{ mA}$
 $L_i = 0$ $C_o = 100 \mu\text{F}$
 $L_o = 100 \text{ mH}$

Alternative Flow Sensor Input Module Connections for connection to a Rosemount Pressure Sensor 3051S to Certificate No. Baseefa05ATEX0193U

$U_o = 16.5 \text{ V}$
 $I_o = 242 \text{ mA}$
 $P_o = 1 \text{ W}$
 $C_i = 0$
 $L_i = 0$
 $C_o = 6.9 \mu\text{F}$
 $L_o = 4.4 \text{ mH}$
 $L_o/R_o = 468 \mu\text{H}/\Omega$

Based on $U_o = 16.5\text{V}$, using Tables for Group I, and reducing to 50%
 Based on $I_o = 242\text{mA}$, using $0.5 \times L \times I^2 = 260\mu\text{J}$, and reducing to 50%
 Based on formula in Standard, using $R_s = 68.4\Omega$, $e = 525\mu\text{J}$, $U_o = 16.5\text{V}$

RS485 Comms Connections

Terminals B2,B3 w.r.t. B1

$U_o = 6.88 \text{ V}$ $U_i = 12 \text{ V}$
 $I_o = 154 \text{ mA}$ $P_i = 1.41 \text{ W}$
 $P_o = 265 \text{ mW}$ $C_i = 0$
 $C_o = 10 \mu\text{F}$ $L_i = 0$
 $L_o = 4 \text{ mH}$
 $L_o/R_o = 139 \mu\text{H}/\Omega$

Relay Output Connections

$U_i = 23 \text{ V}$